

# Electrical System Design of a 15-Storey Hotel in Alabang, Muntinlupa City

Maria Catherine E. Simpao<sup>1</sup>, Reynaldo H. Gomez Jr.<sup>2</sup>, Michael John M. Villar<sup>3</sup>

<sup>1</sup>Student, Master of Engineering Management, Graduate School Department, Nueva Ecija University of Science and Technology, Cabanatuan City, Nueva Ecija, Philippines

<sup>2</sup>Professor, Graduate School Department, Pampanga State University, Bacolor, Pampanga, Philippines

<sup>3</sup>Professor, Graduate School, Master of Engineering Management, Nueva Ecija University of Science and Technology, Cabanatuan City, Philippines

Corresponding Author: [simpaome@gmail.com](mailto:simpaome@gmail.com)

**Abstract:** This paper presents the comprehensive electrical system design for a 15-Storey Hotel located in Alabang, Muntinlupa City. The study focuses on creating a design that is safe, reliable, and cost-effective, adhering to the Philippine Electrical Code (PEC) and international standards (IEEE/NEC). The scope encompasses load computation, transformer sizing, and advanced system studies including harmonic analysis, short circuit calculations, protection coordination, and arc-flash hazard analysis. The system employs a 2000 kVA pad-mounted oil-type transformer stepping down 34.5 kV utility power to 0.230 kV. Results indicate that the proposed design maintains voltage drops within a 3-5% margin and ensures coordinated protection against fault currents up to 76.2 kA at the main bus.

**Keywords:** Electrical Design, 15 Storey Hotel, Short Circuit Analysis, Harmonic Distortion, Protection Coordination, Arc-Flash Analysis, Philippine Electrical Code.

## 1. Introduction

The rapid urbanization of Alabang, Muntinlupa City, requires high-density commercial infrastructures equipped with robust electrical systems. This report details the design for a 15-storey hotel, which includes a three-level parking area, a grand lobby, a restaurant, and luxury guest rooms.

The primary objective is to develop an electrical distribution network that meets the "CARS" criteria: Capability, Availability, Reliability, and Stability. The system is supplied by the local utility (Meralco) at a primary voltage of 34.5 kV, connected to a 2000 kVA power transformer stepped down to 0.230 kV. This research provides a technical benchmark for Professional Electrical Engineers regarding the impact of nonlinear loads and fault duty calculations in high-rise applications.

## 2. Design Methodology and Assumptions

The conceptual framework follows a systematic data collection and design coordination process.

### A. Load Categorization

Loads are categorized into lighting, receptacle outlets, and motor loads (HVAC, fire pumps, and elevators). Lighting loads are treated as continuous (100% Demand Factor), while power

outlets and HVAC equipment are assigned an 80% Demand Factor per PEC 2017 Table 2.20.3.5.

### B. Key Assumptions

- Initial Power Factor: 85% lagging.
- Motor Efficiency: 85% (assumed in the absence of manufacturer data).
- Transient Reactance ( $X''_d$ ): 28% for motors <50 HP; 20% for 50-150 HP; 25% for lumped motor loads.
- System Grounding: Minimum 80mm<sup>2</sup> copper system grounding conductor.

## 3. System Analysis and Calculations

### A. Load Computation and Transformer Sizing

The total connected load was calculated at 1,645.02 kVA. Applying demand factors resulted in a maximum demand of 1,332.00 kVA.

Total Current ( $I_{total}$ ): 3,865.49 A

Transformer Rating: Using the formula

Rating =  $1.732 \times kV \times I_{total} \times 1.25$ ,

the required capacity is 1,970.47 kVA. A 2000 kVA, 3-Phase, 34.5 kV/0.230 kV pad-mounted transformer was selected.

### B. Harmonic Analysis

With the inclusion of non-linear loads (Variable Speed Drives for chillers and elevators), current distortion was evaluated.

- Total Harmonic Distortion (THD): Evaluated at 0.199% for current and 0.345% for voltage at the 0.230 kV bus.
- Compliance: Results fall within IEEE 519 limits (7.0% limit for the 14.36 RSC category).

### C. Voltage Drop Computation

Voltage drop was calculated using the formula:

$$V_{DLL} = 1.732 \times L \times I \times (R \cos \phi + X \sin \phi)$$

- Transformer to LVSG: 3.02% drop (calculated at

6.95 V).

- Branch Circuits: Maintained below the 3% threshold for furthest outlets.

#### D. Short Circuit and Fault Duty

Using the Per-Unit (p.u.) method with a 10 MVA base:

- Utility Impedance ( $Z_u$ ):  $0.00425 + j 0.03094$  p.u.
- Highest Fault Current at Main Bus (Bus 1): 76.208 kA.
- Recommended Interrupting Capacity: 130 kAIC for the Low Voltage Switchgear (LVSG).

#### E. Protection Coordination

Time-Current Curves (TCC) were developed to ensure selectivity between the 30E primary fuse and the 6300A Main Air Circuit Breaker (ACB). A Coordination Time Interval (CTI) of 0.75 seconds was established to ensure that downstream faults do not trigger a total building blackout.

#### F. Arc-Flash Hazard Analysis

Arc-flash boundary and incident energy were calculated to determine Personal Protective Equipment (PPE) requirements.

- Arcing Current ( $I_a$ ): 17.6496 kA at the LVSG.
- Incident Energy ( $E$ ): 3.9790 cal/cm<sup>2</sup>.
- PPE Category: Category 1 (Arc-rated clothing with minimum 4 cal/cm<sup>2</sup> rating).
- Flash Protection Boundary: 1.1131 meters.

### 4. Conclusion and Recommendations

The electrical system design for the 15-Storey Hotel successfully meets the stringent safety and reliability requirements of the Philippine Electrical Code.

#### A. Main Findings:

- A 2000 kVA transformer is sufficient to handle the peak demand while allowing for future expansion.
- The short circuit level of 76.2 kA requires high-performance circuit breakers; an 85 kAIC rating is recommended for distribution panels and 130 kAIC for the main LVSG.
- Harmonic levels are well within the permissible limits of IEEE 519, minimizing the risk of equipment overheating.
- Arc-Flash hazard at the main bus requires personnel to wear Category 1 PPE during live maintenance.

#### B. Recommendations:

- Strict adherence to the periodic preventive maintenance schedule for the 6300A ACB to ensure the calculated CTI remains valid.
- Use of THW-type conductors to withstand high-humidity conditions typical of the project location.

### References

- [1] Institute of Integrated Electrical Engineers (IIEE), Philippine Electrical Code (PEC) Part 1 2017 Edition.
- [2] IEEE Std 141-1993, IEEE Recommended Practice for Electric Power Distribution for Industrial Plants.
- [3] IEEE Std 242-2001, IEEE Recommended Practice for Protection and Coordination for Industrial and Power Systems.
- [4] IEEE Std 1584-2002, IEEE Guide for Performing Arc-Flash Hazard Calculations.
- [5] NFPA 70E, Standard for Electrical Safety in the Workplace.